

**President's Response  
Campus Issue 24-25-05**

**Committee or Individual:** Hirdeyjeet Singh

Date Submitted: 11/15/24

**Issue or Concern:** Non-Functional Automatic Doors in Rodda Hall

**Summary of Issue:** Some automatic doors in Rodda Halls do not work and some stop functioning at certain times.

**Action Taken:**

12/05/24: Campus Issue was submitted to Executive Council and discussed. Executive Council referred to VPA Campbell to work with Operations and FM.

01/08/25: VPA Mitch Campbell agrees to confer with Operations and FM to get status update on the doors.

02/05/25: VPA Mitch Campbell responds with feedback about automatic doors. The automatic external doors have been problematic. The College is contracting with a vendor to assess the doors and help develop a solution, which may involve changing the technology of the doors from wave technology, which involved motion detection to activate the door to push-button technology which is more reliable. Each building is required to have one door that is ADA compliant. The east-facing door in RHN is such a door. It uses the push-button technology and has been reliable.

**President's Response to Executive Council:**

Executive Council has discussed this issue, and, given their guidance, I have received feedback from VPA Mitch Campbell. The automatic doors have had ongoing challenges with reliability. I am pleased that Operations is seriously assessing the technology for the automatic doors with the potential to replace them.

Campus Issue 24-25-05 is closed.

Albert Garcia  
Albert Garcia, President

03/05/25  
Date