

**President's Response
Campus Issue 25-26-02**

Committee or Individual: Vice President of Student Senate, Kuyper Holland
Date Submitted: September 09, 2025

Issue or Concern: Cloudy Water in Refill Station

Summary of Issue: The water from the refill station on the second floor of Rodda Hall North came out cloudy and white. There is a question as to whether this is a health issue.

Action Taken:

10/02/02: The campus issue was presented to Executive Council. The Council requested that President Garcia research the issue with Vice President of Administration Mitch Campbell and/or Director of Operations Debbie Turner.

10/9/25: The issue was sent to Debbie Turner and Operations to inquire about water testing. Operations responded that water dispensers are tested regularly and that cloudy water indicated aeration and not contamination. All tests have concluded that water from the dispenser on the second floor of Rodda South and others around campus is safe for consumption.

President's Response to Executive Council:

Based on the response from Campus Operations about testing of the water, I am comfortable closing this issue. Thank you to our Student Senate vice president for raising the question about drinking water safety. It is always good to make sure we are diligent about such matters.

Campus Issue 25-26-02 is closed.

Albert Garcia
Albert Garcia, President

11/21/25
Date